

# Inspection Status Detail

Use Back button to select another inspection or select Options Menu to choose another building permits option.

<b>Parcel ID:</b>	NC29-SUM10- 4- 12-001	<b>Address:</b>	301 STARSHINE DR
<b>Application Date:</b>	04/26/12	<b>Owner:</b>	CUSTOM BUILDERS OF OK,LLC.
<b>Application #:</b>	12 - 1882	<b>Application Type:</b>	1 FAMILY, NEW
<b>Inspections for Permit Number:</b>	000 000 ELEC 00 - ELECTRICAL PERMIT		
<b>Inspection type/sequence:</b>	ELEC, ROUGH/PERMANENT SERVICE/0001		
<b>Inspector assigned:</b>	KEVIN POTTS		
<b>Schedule Date:</b>	06/26/12		
<b>Results Date:</b>	06/26/12		
<b>Results Status:</b>	DISAPPROVED WITH PENALTY		

## Request Comments:

## Result Comments:

1. Add receptacle to cover wall space in SE corner of master bedroom.
2. Secure switch box to stud, box is located to left of breaker panel.
3. Cap conductors on load side of refrigerator receptacle at next box or remove conductors from receptacle.
4. Add receptacle to cover NW corner of living room wall space.

